



Certificate of Compliance

Certificate: 70049278 **Master Contract:** 189724
Project: 80136283 **Date Issued:** 04/06/2023
Issued to: M.G.M. Motori Elettrici S.p.A.
Via Fermi 44
Assago (MI), Milano 20090
Italy
Attention: Francesco Ghieri

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Majid Ali
Majid Ali

PRODUCTS

C421101 MOTORS AND GENERATORS - Motors and Generators
C421181 MOTORS AND GENERATORS - Certified to US Standards

Component type motors, squirrel-cage induction motors, foot and/or flange mounted to enclosure with changeable position.

Models	Ambient Temp (°C)	Enclosure	Frame Size	Frequency (Hz)	Insulation Class	Phase	Pole(s)	Power (kW max)
--------	-------------------	-----------	------------	----------------	------------------	-------	---------	----------------



Certificate: 70049278

Master Contract: 189724

Project: 80136283

Date Issued: 04/06/2023

Series BAH, Series BAHX, Series BMX, Series SM, Series SMS, Series SMX, Series BM, Series BA, Series BS, Series BAX	40	TEFC	56-63-71-80- 90-100-112- 132-160-180- 200-225-250- 280	max. 120	F	3	2, 4, 6, 8, 12, 2/4, 4/8, 2/6, 2/8, 4/6, 4/12, 2/12, 4/16	from 0.04 to 90
Series BA, Series BAH, Series BAHX, Series BAX, Series BM, Series BMX, Series BS, Series SM, Series SMS, Series SMX	40	TEFC	56-63-71-80- 90-100-112- 132-160-180- 200-225-250- 280	max. 120	F	3	2, 4, 6, 8, 12, 2/4, 4/8, 2/6, 2/8, 4/6, 4/12, 2/12, 4/16	from 0.04 to 90

Models (cont.)	Voltage (V max)
Series BAH, Series BAHX, Series BMX, Series SM, Series SMS, Series SMX, Series BM, Series BA, Series BS, Series BAX	600
Series BA, Series BAH, Series BAHX, Series BAX, Series BM, Series BMX, Series BS, Series SM, Series SMS, Series SMX	600

Note: Intended for use as a component part in other equipment where the acceptability is determined by the CSA Group.



Certificate: 70049278

Master Contract: 189724

Project: 80136283

Date Issued: 04/06/2023

Note: Motors could also be marked for intermittent duty service, S2 or S3, provided that the input rated current is less than or equal to the value indicated for the continuous duty service S1.

Note: Following models are suitable to be used in conjunction with Speed drives: BA71, BA90, SM71 / BM71 – SM90 / BM 90, BA/BM/SM 71 A4 - BA/BM/SM 71 B4 - BA/BM/SM 80 A4 - BA/BM/SM 80 B4 - BA/BM/SM 90 SA4 - BA/BM/SM LA4. With max. 120Hz



Certificate: 70049278

Master Contract: 189724

Project: 80136283

Date Issued: 04/06/2023

APPLICABLE REQUIREMENTS

CSA C22.2 No. 100-14 (R2019) - Motors and generators

UL 1004-1-2020(Second Ed.) - Standard for Safety Rotating Electrical Machines- General Requirements

UL 1004-8 (Second Edition) - UL Standard for Safety for Inverter Duty Motors, UL 1004-8,Second Edition, Dated November 13, 2013



Certificate: 70049278


Project: 80136283

Master Contract: 189724

Date Issued: 04/06/2023

Notes:

Products certified under Class C421101 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 70049278

Master Contract: 189724

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80136283	April 06, 2023	Update to Report 70049278 to cover the addition of new ratings for series BA71 and BA90 and extension to UL 1004-8 requirements and CSA 22.2 No.100-14 cl.13, inverter duty machines.
80124071	November 14, 2022	Update to Report 70049278 to cover the addition of alternate impregnation varnish on electromagnet series BA provided in class A (105°C) and corrections to report.
80082644	July 13, 2021	Update to Report 70049278 to cover addition of alternate ratings and
80007059	July 30, 2019	Update to Report 70049278 to cover report corrections, addition of model SMS 80 B4 KW 0,75 - Intermittent duty - IP56 or lower protection degree, components, corrections of models names
70200721	March 07, 2019	Update to Report 70049278 to cover to cover the addition of motor series from CSA report 1309537 and CSA report 1282269, addition of alternate materials and components, corrections to the report and review of the certification attachments.
70081823	June 29, 2016	Update to Report 70049278 for the addition of Intermittent duty cycle S2 or S3.
70049278	March 08, 2016	Original Certification of Component type motors, series SMX,BMX,BAX,BAHX, 3 ph, 600V max, 50/60Hz , from 0.75 KW to 90 KW max., ambient temperature 40 °C, 2/4/6 poles, squirrel-cage induction motors, tefc, foot and/or flange mounted to enclosure with changeable position, Insulation Class F, frame sizes 80-90-100-112-132-160-180-200-225-250-280 according to the requirements of CSA 22.2 No.100-14, UL1004-1 (2nd ed.).